Attestation

DE-UZ 176

On the 29th of June 2026, Eurofins Product Testing A/S received a sample of a wood-based panel with the product name:

Viroc

supplied by

VIROC PORTUGAL SA - INDUSTRIAS DE MADEIRA E CIMENTO,S.A.

The emissions were tested according to DE-UZ 176 (Edition of January 2013 - Version 8). Sampling, testing and evaluation were performed according to EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 (see the test report no. 392-2026-00351001_A_EN)

Evaluation of the emission test result according to DE-UZ 176:

- The sum of VOC ("TVOC") after 3 days was in compliance with the limit of ≤ 3 mg/m³.
- The sum of VOC ("TVOC") after 28 days was in compliance with the limit of ≤ 0.3 mg/m³.
- The sum of SVOC after 28 days was in compliance with the limit of ≤ 0.1 mg/m³.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was in compliance with the limit of ≤ 1.
- The sum of VOC without LCI-value after 28 days was in compliance with the limit of ≤ 0.1 mg/m³.
- Carcinogenic substances were not detectable after 3 and after 28 days.
- The concentration of formaldehyde after 28 days was in compliance with the limit of ≤ 0.05 ppm.

This attestation does not entitle to use the Blue Angel DE-UZ 176 label. For the use of the DE-UZ 176 label a license has to be applied for at the DE-UZ. A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals are fulfilled.

24 September 2026

Rasmus Verdier
Analytical Service Manager